

CHIMNEY SHROUD DETAIL

NOTE:

1. KEEP MINIMUM 6" CLEARANCE ALL AROUND VENT TERMINATION TO SURROUNDING. THIS INCLUDES BOTTOM SIDE OF TERMINATION AS WELL.
2. IF THE TOP OF THE SHROUD IS ENCLOSED, KEEP MAXIMUM 10" CLEAR FROM TOP OF TERMINATION TO SHROUD CEILING.
3. FOR OPENINGS IN THE SHROUD, MAKE SURE TO ALLOW FOR ENOUGH AIR FLOW SPACE TO RELEASE THE EXHAUST GASES AND ALLOW THE VENT TO OPERATE PROPERLY.
4. CENTER OF OPENINGS MUST BE ALIGNED TO CENTER OF THE TERMINATION CAP DISPLAYED IN "X" AND "Y".

